Government of Jammu & Kashmir

Office of the Executive Engineer, Jal Shakti (PHE) Mechanical Division (North) Sopore Email ID: phe.mdns@gmail.com Website: phekashmir.com

> No.: PHE/MDNS/DB/ 3946-53 Dated: 24-00-023.

M/s Buhroo Mechanical Private Ltd. Azad Gunj Baramulla-193101

GST No: 01AAKCB6235H1ZY

Cell No: 7006302261

Adv. Cost:	Rs 41.354 Lacs
Allotted Cost:	Rs 39.612 Lacs

Subject:

Electrical and mechanical works to be carried at WSS Kanhar Colony Botengo under JJI

Reference:

This office e-NIT No.: e-NIT No. 37 of 2022-23, S. No. 02 issued unc 1. endorsement No.: PHE/MDNS/DB/5443-55, dated: 07-01-2023 and this off corrigendum No. PHE/MDNS/DB/5847-49, dated 28-01-2023:

Authorization awarded by Member Secretary DJJM Superintending Engineer 2. Shakti (PHE) Hydraulic Circle Baramulla/Bandipore HQ at Sopore issued vide

SE/Hyd/DB/2135-49, dated: 30-05-2023.

Dear Sir,

For and on behalf of Lt. Governor of J&K U.T contract for execution of "Electrical mechanical works to be carried at WSS Kanhar Colony Botengo under JJM" is hereby awarded to firm on the quoted/negotiated rates, as per 'General Terms & Conditions' and 'Schedule of cost quantities' annexed herewith as under:

\*\*\*\*\*\*

Annexure A: General Terms & Conditions.

Annexure B: Schedule of cost and quantities.

Encl. \_\_\_ leaves

xecutive Engineer hakti HE Mechanical Division (No. Sopore

Copy to the:

1. Chief Engineer Jal Shakti (PHE) Department Kashmir, Srinagar for favour of information.

2. District Development Commissioner \_\_\_\_\_\_\_, for favour of information.

3. Superintending Engineer Jal Shakti (PHE) Mechanical Circle (North) Srinagar, for fav information.

4. Superintending Engineer Jal Shakti (PHE) Hydraulic Circle \_\_\_\_\_\_ HQ at \_\_\_\_\_, for of information.

5. Executive Engineer Jal Shakti (PHE) Division \_\_\_\_\_\_, for favour of information.

6. Provisional Head, TPIA JJM Kashmir, (WAPCOS Limited) Corporate Office 76-C Institution Sector-18 Gurugram-122015 (Haryana) for favour of information.

7. Assistant Executive Engineer Jal Shakti (PHE) Mechanical Sub-Division \_\_\_\_\_\_ for inform necessary action.

8. File concerned.

No: 7006300980

## Annexure "B" Schedule of cost and quantities to this office Allotment Order No: PHE/MDNS/DB/3946-57, dated: 24-00-023.

me of work: Electrical and Mechanical works to be carried out at WSS Khanhar Colony Botengo under JJM.

S.	Description of Work / Item(s)	No.of Qty	Units	Rate	Amount
1	Design, supply, providing, installation, successful testing and commissioning of vertical turbine pumping unit as per IS 1710 driven by VT motor for pumping water at Stage 1st of following parameters.  *Site Condition Altitude = 1580 Meters/Greater (AMSL) Ambient Temperature = +40°C to - 15°C Relative Humidity = 60%  *Type of water = Raw water having specific gravity of unity average.  *Quality of water = Raw water with silt having medium to coarse sand.  *Sump/liner Bed Level = 4.5 m/otherwise specified below from Machine floor level  *Water column in liner/sump = 2 m/as specified otherwise above from sump/liner bed level A.PUMP  1.Discharge = 5000 GPH  2.Type = Self water lubricated, VT pump, open line shaft.  3.Liquid to be handled = Raw Water  4.RPM = 1450  5.Head = 170 M  6.Efficiency = Not less than 50%  7.Impeller = Semi-enclosed mixed flow all bronze/stainless steel  8.Line shaft/head shaft = Stainless steel	Job	2	5,89,881.60	11,79,763.2
	9.Length of each line shaft = 1 m maximum 10.Total length of line shaft = 10 m/as specified (excluding Head shaft) 11.Impeller shaft = Stainless steel 12.Line shaft bearing = Cut less rubber/ Neoprene rubber 13.Line shaft coupling = Stainless steel 14.Suction Strainer = MS fabricated 15.Suction Bowl/Bell mouth= Cast Iron 16.Pump Bowl = Cast iron 17.Column pipe = Mild Steel of wall thickness not less than 8mm flanged type in assorted lengths 18.VT Pump to be designed with minimum number of stages.				
	B.Prime Mover  1.Type = Vertical hollow shaft, AC squirrel cage induction motor  2. Rating = Corresponding to the head and discharge not less than 30 HP.  3.Power Supply = 03 Phase, 415V+ 15% AC  4.Frequency = 50Hz + 3%  5.RPM = 1450 Synchronous  6.Efficiency = Not less than 90%  7.HP = As per requirement  8.Class of insulation = F or above  9.Type of duty = Continuous  10.Type of rotor = suitable among single squirrel cage / double squirrel cage , single or double skewed squirrel cage.  11.GD2 = suitable for above parameters.  12.Motor thrust bearing = Anti friction ball /roller bearing  13.Method of starting = star/delta  The motor should be able to with stand fluctuations in voltage and should be conforming to latest IS specifications.  C.Accessories  *Each pump unit shall be provided with suitable discharge head with proper stiffening box arrangement, non-reverse ratchet, coupling etc as per standard specification besides all other accessories required for satisfactory performance and mechanical works required for installation of pumping unit at site are included in the job.  Note: Providing of test certificate & Characteristic Curve of pumping equipment is compulsory and pumping unit is to be approved from the concerned authority before procuring.				-





2	Providing/supplying and fitting of 100mm dia G.I flanged Rising Main at site. The Pipe shall be hot dip Galvanized, class-C confirming to IS 1239. The Job includes providing and fitting of M.S Flanges conforming to BIS 6392/1997 Table 17 (Rating PN16) for Y junction and washout. The flanges shall be double welded both from inside and outside of the pipe using standard electrode of reputed make.  Size: 100  Class: C (Heavy)  Flanges (as per IS 6392/1997 Table:17)  Thickness shall conform to IS 6392 Part 1st Table-17. The flange welding shall be carried out in double layers using reputed make electrodes to form strong welding joint.  Welding Electrode  DC Arc Welding using welding electrode having diameter not less than 4mm.  Nuts and Bolts  Nuts and Bolts (conforming to IS:1363 Part 1st)  Rubber Insertion Gaskets  Rubber Insertion Gaskets (conforming to IS: 638/79) to be used between flanged joints.	Meters	30	2,189.00	100 100 100 100 100 100 100 100 100 100
3	Cutting of hot dip galvanized 100mm dia G.I., C-Class pipe across the section by dint of pipe cutter/ gas cutter. The job also includes Providing and welding of M.S flanges to the two ends of pipe. The Thickness of flange shall conform to IS 6392 Part 1st Table-17. The flange welding shall be carried out in double layers using electrodes to form strong welding joint by dint of DC arc welding. The job further includes Providing and Fitting of nuts and bolts (conforming to IS:1363 Part 1st) and Rubber Insertion Gaskets (conforming to IS: 638/79) to be used between flanged joints	Job	10	1,544.00	15,440.0C
4	Fabrication, Providing and fitting of 100mm dia Y- junction having 1m length (Approx.) of each arm to be fabricated out of hot dip galvanized G.I, C-Class pipe. The job also includes Providing and welding of M.S flanges to the ends of each arm. The Thickness of flange shall conform to IS 6392 Part 1st Table-17 fastened with weld joints on three ends. The flange welding shall be carried out in double layers using reputed make electrodes to form strong welding joint by dint of DC arc welding. The job further includes Providing and Fitting of nuts and bolts (conforming to IS:1363 Part 1st) and Rubber Insertion Gaskets (conforming to IS: 638/79) to be used between flanged joints.	Job	1	9,737.00	9,737.01
5	Providing and fitting of DN100 Ductile Iron double flanged PN 1.6/16, non-rising spindle soft seated glandless gate/ sluice valves as per IS14846 for regulating the water supply outside the pumping units.  The body and bonnent of the valve shall be of ductile iron, wedge with fully vulcanized EPDM rubber(Approved for drinking water) and NBR seal. The Gate/Sluice valve shall be compatible for buried applications and shall be safe to install in both horizontal and vertical positions It shall have electrostatic epoxy coating(approved for drinking water) both inside and outside of the valve. The valve shall be supplied along with hand wheel.  Cost on account of Nuts, bolts, gaskets, etc required for the job is included in the scope of work. The job includes providing and fitting of 02 nos. M.S flanges (Table flanges) perfectly adaptable to the inbuilt flanges of the valve which shall be fitted with rising main of the pumping unit at appropriate spots as per site requirement. The job includes the cost on account of P/F of nuts, bolts and gasket required for the job.	No	3	19,094.00	57,282.0
6	Providing and fitting of 100mm dia Ductile Iron double flangedPN:1.6/16, Slanted seat swing check valve( NRV) as per IS 5312. The body shall be of ductile cast iron with fully encapsulated vulcanized EPDM rubber(Approved for drinking water). The valve shall be compatible for buried applications and shall be safe to install in both horizontal and vertical positions. It shall have electrostatic epoxy coating (approved for drinking water) both inside and outside of the valve.  Cost on account of Nuts, bolts, gaskets, etc required for the job is included in the scope of work. The job includes providing and fitting of 02 nos. M.S flanges (Table flanges) perfectly adaptable to the inbuilt flanges of the valve which shall be fitted with Rising main of the pumping unit at appropriate spots as per site requirement. The job includes the cost on account of P/F of nuts, bolts and gasket required for the job.	No	2	20,581.00	<b>41,162.</b> C
7	Fabrication, providing and fitting of 100mm dia 90-120 degree bend/elbow to be fabricated out of Class B GI pipe, 1 m length and flanged on both ends and to make it leak proof. The flanges shall be M.S Flanges conforming to BIS 6392/1997 Table 17 (Rating PN16) and welded on both sides. The job includes nuts, bolts, gaskets etc. as per site requirement.	job	7	3,614.00	25,298.
8	Fabrication, providing and fitting of washout Tee 100mm with arm length 1.2 feet each (Approx.). The Tee shall be fabricated out of G.I C-class pipe with M.S Flanges conforming to BIS 6392/1997 Table 17 (Rating PN16) fastened with weld joints on three ends. The size of the Tee is given Below:	Job	1	5,122.00	5,122.

	creation of pole mounted, outdoor type 100KVA Level II Electric Sub Station as per the technical specifications given here under -				
	Specifications conforming to IS: 1180 (Part 1) 2014 with latest amendments.			1	l l
	Type: HT/LT Transformer		1		
1	Type of cooling: ONAN.		1 1		1
			1 1		1
١	Operating conditions:		1 1		1
- 1	Input =11000 volts		1 1		1
1	Output =433 volts AC supply in 3- phase.		1 1		1
١	Terminals:		1 1		1
1	Input=3 No. HT bush rods with insulators, washer, nuts etc.				
١			1 1		1
١	Output=4 No. LT bush rods switch insulators, washers, nuts etc.				
	Core: The core shall be of high permeability to reduce core losses and the strips shall be of			1 3043	
	suitable size and gauge.	Job	1	2,09,945.00	2,09,945.00
	Transformer Coils: Suitable number of HT and LT coils in each leg of the core. The transformer	,,,	2	2,03,5 13.00	2,03,3 13.00
	coils shall be fabricated out of superior quality aluminum wire/strips, properly wound. The HT				1
	transformed to add to superior quality autinitian wire/strips, properly wound. The HT				
	transformer is completely filled with suitable grade transformer oil up to required level. The job				
	includes carriage, and all leads and lifts involved.			(i) o	1 - 1
	The HT transformer shall be of reputed make from an ISO certified company as per relevant				
	standards and a test certificate shall be provided before installation. The transformer shall also				
	be provided with break as Ellevite 18 and the provided before installation. The transformer shall also				
	be provided with breather fill with silica jell crystals, conservator with oil level indicator,				
	explosion vet and adequate radiator fins/ Tubes. The impedance of transformer shall be as per		100		
	13: 1180 (Part 1) 2014 with latest amendments.				
	NOTE: The scope of the work shall include obtaining of necessary inspection/clearance				n 1
	certificate from the concerned described to the constraint include obtaining of necessary inspection/clearance				
	certificate from the concerned department for all the required equipment. The testing and			The second second	
	commissioning shall be completed only after obtaining above certificate.				
	Supply, installation, erection of 9 mtrs long H.T pope of specifications ST- 410 (sp-33) . The job further	Property and the		the state of the s	A THE RESERVE AND A STATE OF THE RESERVE AND A S
	includes drilling of holes for its storig H.T. pope of specifications 31- 410 (sp-33). The job further				Star and a second
	includes drilling of holes for installation of various accessories wherever required the job further includes	Nos	20	20,686.00	4,13,720.00
-	G.I wire earthing of pole as per REC standard.				
	Cement Bottoming 1:2:4 mix as per REC standards 0.5 cum/pole	Job	20	4,582.00	91,640.00
	G.I V cross with top Bracket including clamps	1.15000000	338.2	163.90	
	11 KvA Polymeric Insulators 12 kV ,5kN , Lighting impulse 75 kV Positive and 80 kV Negative with	Kgs	338.2	163.90	55,430.98
	Treepage distances 12 kV ,5kN , Lighting impulse /5 kV Positive and 80 kV Negative with	Nos	66	347.00	22,902.00
-	creepage distance 320mm	1403	00	317.00	22,502.00
	P/F of Galvanized nuts, bolts of various sizes as per site requirement.	Kgs	29	142.00	4,118.00
	P/F of Danger plate with clamps	Nos	20	153.00	3,060.00
	P/F of Anti climbing Device with clamps		20	136.00	
,	Painting of pales with Links	Nos			2,720.00
_	Painting of poles with Red Oxide coating	Ltr	20	306.00	6,120.00
3	Painting of poles Aluminum paint	Ltr	20	510.00	10,200.00
9	P/F of Stone pad (300mm x300mm x75mm)	· Nos	20	244.00	4,880.00
	Providing and fitting of ACSR as per IS 398 (part-2) 1996 for 50 Sq.mm ACSR (Galvanised steel reinforced)		I make		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
)	for fitment of various accessories	m	1800	60.00	1,08,000.00
			252	212.00	74 574 44
	GI Channel/Angle/Flat of sizes including clamps	Kgs	352	212.00	74,624.00
	Supply, Installation, Testing and commissioning of Polymeric Gang operated Air break switch, outdoor				
	type, triple pole, suitable for vertical installation, single break provided with locking arrangement at both				
					The second
	ON and OFF position consisting of HT post double insulator, copper or copper alloy high pressure heavy	Set	2	11,730.00	23,460.00
			A STATE OF THE PARTY OF THE PAR	V TOTAL TOTA	
	contact assembly, rod with bearings, operating handle and 2 length of 32mm dia. GI pipe conforming to				
Н	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.				
4	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs .				
- 1	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and	Nos	6	357.00	
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm	Nos		357.00	2,142.00
-	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA		6		2,142.00
-	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm	Nos No		357.00 7,754.00	2,142.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inleuding providing and fitting of DO set		6		2,142.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation,		6		2,142.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of		6		2,142.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of		6		2,142.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inleuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all		6		2,142.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets		6		2,142.00 7,754.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.	No	6	7,754.00	2,142.00 7,754.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets	No	6	7,754.00	2,142.00 7,754.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.	No	6	7,754.00	2,142.00 7,754.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm	No	6	7,754.00	
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg	No	6	7,754.00	2,142.00 7,754.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg	No	6	7,754.00	2,142.00 7,754.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor	No	6	7,754.00	2,142.00 7,754.00 31,386.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X60mm), nuts and bolts, 2 N0- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod	No	6 1	7,754.00	2,142.00 7,754.00 31,386.00
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor total control of the complete of the complete.	No Nos	3	7,754.00 10,462.00 5,018.00	2,142.00 7,754.00 31,386.00 20,072.0
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X60mm), nuts and bolts, 2 N0- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod	No	6 1	7,754.00	2,142.00 7,754.00 31,386.00 20,072.0
1 1 2 5	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X60mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 3, 7/3.15 mm dia. G.I stranded wire complete.	No Nos	3	7,754.00 10,462.00 5,018.00 434.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0
1 2 2 4	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 28, 7/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape	Nos Set Nos LS	6 1 3 4 6 1 1	7,754.00 10,462.00 5,018.00 434.00 1,105.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As.specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 3, 7/3.15 mm dia. G.I stranded wire complete.  Prof of Wedge connectors / PG Clamps  Bundry Items like Alumunium Lugs, Jumprs, binding Tape  Se sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)	Nos Set Nos	6 1 3 4 6 1 10 10 10 10 10 10 10 10 10 10 10 10 1	7,754.00 10,462.00 5,018.00 434.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor colate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod (27/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape  15 sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)  Heat Shrinkable Outdoor cable termination Kit	Nos Set Nos LS	6 1 3 4 6 1 1	7,754.00 10,462.00 5,018.00 434.00 1,105.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0 8,180.
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor colate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod (27/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape  15 sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)  Heat Shrinkable Outdoor cable termination Kit	Nos  Set  Nos  LS	6 1 3 4 6 1 10 10 10 10 10 10 10 10 10 10 10 10 1	7,754.00 10,462.00 5,018.00 434.00 1,105.00 818.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0 8,180.
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 27/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape  Ses sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)  Heat Shrinkable Outdoor cable termination Kit  Providing & Fitting of 35 sq mm Single Core Copper Conductor (Flexible) PVC Insulated Heavy	Nos  Set  Nos  LS	6 1 3 4 6 1 10 10 10 10 10 10 10 10 10 10 10 10 1	7,754.00 10,462.00 5,018.00 434.00 1,105.00 818.00	2,142.00 7,754.00
1 1 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As. specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor olate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 2x 7/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape  35 sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)  Heat Shrinkable Outdoor cable termination Kit  Providing & Fitting of 35 sq mm Single Core Copper Conductor (Flexible) PVC Insulated Heavy Outy Industrial Cables (Unsheathed), 1100 Volts Conforming to IS: 694- for connecting motors	Nos  Set  Nos  LS  m  Nos	6 1 3 4 6 1 10 2	7,754.00 10,462.00 5,018.00 434.00 1,105.00 818.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0 8,180.
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor plate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 27/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape  Ses sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)  Heat Shrinkable Outdoor cable termination Kit  Providing & Fitting of 35 sq mm Single Core Copper Conductor (Flexible) PVC Insulated Heavy	Nos  Set  Nos  LS	6 1 3 4 6 1 10 10 10 10 10 10 10 10 10 10 10 10 1	7,754.00 10,462.00 5,018.00 434.00 1,105.00 818.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0 8,180.
	IS 1818 1961, 06 No. of insulators, rated voltage 11KV 200A complete as per IS specs.  11 kV polymeric composite Disc Insulator 12 kV, Min failing load 45kN, Lighting Impulse 75kV Positive and 80 kV Negative, creepage distance 320mm  Supply, Installation, Testing and commissioning of Gapless Surge arrestor station class, 10KA, 9KV, LA With polymer housing, Station Type inlcuding providing and fitting of DO set  Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As. specified),  Length : 2000 mm  Back fill compound : 30 kg  Providing and fitting of Galvanized stay set with 50 X 8 mm Stay Clamp, Guy insulator (2no.), Anchor olate (200X200X6mm), nuts and bolts, 2 NO- turn buckle, 1.8 m long, 16 mm diameter solid G.I stay rod 2x 7/3.15 mm dia. G.I stranded wire complete.  Pof of Wedge connectors / PG Clamps  Sundry Items like Alumunium Lugs, Jumprs, binding Tape  35 sq mm AB(HT) Cable (3x35+1x70 sqmm) XLPE (11 kV, 3C+Earth)  Heat Shrinkable Outdoor cable termination Kit  Providing & Fitting of 35 sq mm Single Core Copper Conductor (Flexible) PVC Insulated Heavy Outy Industrial Cables (Unsheathed), 1100 Volts Conforming to IS: 694- for connecting motors	Nos  Set  Nos  LS  m  Nos	6 1 3 4 6 1 10 2	7,754.00 10,462.00 5,018.00 434.00 1,105.00 818.00 8,994.00	2,142.00 7,754.00 31,386.00 20,072.0 2,604.0 1,105.0 8,180.0

	Providing, installation, testing of power service cable for working voltage up to and including				Training Training
32	1100 volts; 95 sq mm armored aluminum 3.5 core cable for working voltage up to and including HT/LT transformer to cubical panel. Cost includes laying of cable in trenches in Pvc conduit where ever it is to be laid underground as per site requirement included is termination of ends with suitable Aluminum tube terminals dully crimpled & taped.  NOTE:- The cable terminal ends for connection to switchgear at various requisite points shall be Al. Thimbles of reputed make and of appropriate size and connected by hydraulic crimp tool	М	120	837,00	1,00,440 (x,
	only.				
33	Providing, fitting, testing and commissioning of 75KVA voltage stabilizer as per specifications below:  Type of voltage controller: Manually operated copper wound, 3-phase, AC power supply multi step.  Type of Regulator: Double plate type with electrolytic copper contacts.  Input voltage: 250-400 volts. (3 phase)  Output voltage: 400 ±10% volts.  Frequency: 50 ±3 C/S.  Windings: Electrolytic grade copper of adequate section, vacuum impregnated and Ovendried.  Insulation: Fiber glass insulations to tested parameters.  Cooling: Naturally, Oil cooled  Temp. Rise (Max): 30°C above ambient  Mounting: On Uni-directional wheels.  Correction rate: 30 volts per step  Wave form distortion: virtually nil  Duty cycle: 100% continuous.  Enclosure: MS sheet enclosure in pressed CGR Sheet powder coated with radiators.  Core laminates: High grade, low eddy loss, grain oriented silicon steel laminations.  Load: Three phase induction motor load.	Job	2	1,63,721.00	3,27,442.00
	Load Amperes (continuous)  Overload in 24-hours operation: 10% above continuous Ampere rating.  The voltage stabilizer shall have T-oil level indicator gauge preferably glass type tube or otherwise visible to naked eye. The top of the container to have a display panel for housing 02 numbers Digital voltmeters (0-500V) along with 4-way selector switch and set of neon indicators for incoming and outgoing phases (06 No's).  Insulating media (T. Oil) of 11 KVA grade to be provided and filled up to top level, with dielectric strength of 5 KV at 4m air gap. The T-Oil of specific grade should be provided in separate barrels and filled at site up to top level.  The voltage Stabilizer shall be accepted with manufacturers dully stamped test certificate and shall have name plate with specifications.				
4	Design, manufacturing , providing , fitting, testing & commissioning of Star-delta Motor control gear Panel.  The Star-delta Motor control gear Panel shall be fabricated out of 14 SWG CRCA Sheets Modular, compartmentalized, Free Standing, Floor Mounting, Front hinged doors for indoor use, removable bottom gland plates for incoming cables, dust and vermin proof (IP: 55 protection) with TP Copper Buses as per load , complete with connection, internal wiring, neon indicators for each phase ,starter buttons, name plates, painting ,vents etc. generally as per details furnished below:  Rated Voltage of the Panel —— 440 Volts  Frequency —— 50 HZ  No of Phases —— Three  Enclosure Details —— Free Standing, Floor mounted, Compartmentalized Design.  Material —— CRS  Thickness of sheet steel used —— 02mm  Application —— Indoor  Cable Entry —— Bottom  Painting —— Shade Siemens grey.  a) Main Circuit Breaker incoming combined  Type —— On load 4 pole MCCB  Rating: 250A  Qty —— 2 Nos (for Main and Standby/DG Set Supply)  No. of poles —— 4  Rated operational voltage—— 415 V AC ± 15%  Rated frequency —— 50 ± 3% Hz  Ultimate S.C Breaking cap at (415 volt A C, 50 Hz) —— 50kA	Job	1	3,55,811.00	3,55,811.0

endorsement No.: PHE/MDNS/DB/1455-60, dated: 10-06-2023.  ${\cal A}$ b) Distribution bus bar Type ---- Electric grade Cu with red, blue & yellow tapings of adequate section. Rating ---- 200 Amp c) Change over Switch Qty ---- One Type---- Front Operated on load 4 pole (open execution) Rating ---- 200 Amp d) Circuit Breaker units Type ---- MCCB Qty ---- 2 Nos No. of poles----3 Rated current ---- 200 Amp Thermal release range-Rated operational voltage---- 415 V ± 15% Rated frequency ---- 50 ± 3% Hz Ultimate S.C Breaking capacity at (415 volt A C, 50 Hz) ----50kA Starters (FASD) Power Specification ---- 3 phase, 415 ± 15% v & 50 Hz Contactors: Line Contactor ---- AC3 110 A Delta Contactor -- AC3 110 A Star Contactor ---- AC3 90 A Timer ---- Star Delta Electronic Thermal overload relay - direct/CT operated Suitable/available range Coil Voltage: 220/240V - 2 No's Aux. panel Circuit breaker--- MCCB 63 Amp Qnty--01 no. No. of poles-04 Rated operational Voltage-415+15% Ultimate S.C. Breaking Capacity---35 KA at (415AC,50 Hz) g) Stabilization unit for both starters Qnty-02 no Rating-- 1 KvA single phase automatic voltage stabilizer Input:90V-300 Out Put: 220/240 ( as per coil voltage of contractors) Enclosure— to be housed within the cubical panel in separated chamber with additional meter, LED fitted outer side MCB DP -10A-1nos h) Protection Details: Compact Motor Protection Relay including other related accessories like single phase preventer relay, timer relay, overload-under load, phase difference etc. Display — LED/LCD and all setting is to be done at display Compact motor protection relay Onty :01 nos) Protections: · Flush Mounting with display Last trip data recording Protections: Thermal Overload with pre- alarm Short Circuit Earth fault Phase loss, Unbalance, Phase reversal Prolong starting, Locked Rotor. -Single phase protection- Single Phasing condition- Phase Reversal condition- Phase Unbalance condition **Modes of Operation** i) M-Power module for mobile starters and Earth fault relay as Auxiliary Protection Earth Fault Relay ---- 3 phase Earth fault, ground fault module Range as per requirement MCB --- MCB SP, 10A (10 Ka) j) Water level control relay for including wiring and capsules required at site keeping depth of sump 10 meters in consideration: 01 unit complete (not for production wells) g) Metering Details: Incomers (Panel Mounted) (a) Multi-Function Meters LCD Display (1 No) Voltage of each phase, Current of each phase 3ø power (Active, Apparent), 3ø Power factor Frequency, Energy (b) Analog voltmeter S/S operated (1 No) - Rishabh make. ·(b) Outgoing (Analog voltmeter (0-500) S/S operated (1Nos). Analog Ammeters 0-100 Amp (2Nos) for both starters Each outgoing with S/S CT operated (Rishabh make ) h)M-power module for mobile starter for submersible motor suitable region north India. i) Water level controller Note: Name of Scheme; Allotment No; should be imprinted on the machine with capital letters



					10 0 0 E
35	Providing, installation and testing of manual type triple spur gear chain pulley block along with monorail geared travelling trolley having following features Gears: The hoist shall have precision machine case Hardened alloy steel gear mounted on bearings and housed in a dust proof gear box. The lubrication of gears should be of high viscosity and temperature for longer life of gears.  Load Chain: The load chain be made of high tensile alloy steel having wear resistance and greatest mobility. The chain should be accurately collaborated, tested and have adequate inbuilt factor of safety for safer operation.  Load chain wheel: the load chain well should be double ball bearing supported and specially designed, perfectly machined wheel providing correct grip of load chain to makes the hoist most safe and reliable against any failure. The main specifications of C.P Block are given below:  Make = Reputed make Capacity = 3 ton (P)  No. Of load chain falls = 2 or above  Min. Height of lift = 6 M	Job	1	62,972.00	62,972 00
6	Illumination of Premises:  Providing and erection of 9 Mtr long Hot Dlp Galvanized octagonal pole (single Section) with bottom 150mm, top 75mm wide, thickness 3mm with 70 Microns Zinc coating having inside arrangement for providing of power connection along with following Items.  1)3 Way Terminal Connector 20 Amp.  2)3 No MCB 8 Amp.  The job includes fabrication, providing and fitting of three arm GI structure at the top having 120° angle between arms and each arm having 15° Inclination with respect to horizontal plane. Each arm should be of 2′ length and size and shape appropriate as per requirement of the luminary.  The job also includes providing and fitting of required length of flexible multi strand 2 mm copper wire from each terminal connector to each holding arm.  The pole is mounted on 1:2:4 Cement concreting of size not less than 2′x2′x6″ (cost of concreting not included in the job) using 04 No anchor bolts of required size not less than 7″ in length. The complete job includes earthing in GI Electrode as per relevant IS Code	Job	i	22,226.00	22,226.00
7	Providing, installation, testing and commissioning of area lighting 120 Watt LED (Street Light Type) on top of octagonal pole Having following specs: Input: 90-240 V 50 Hz Power Factor: >0.9 Colour Temperature: 4K - 6.5K Beam Angle: 120* - 170* Lumens: >12000 Operating Temperature: -20*C to 60*C The LED is pressure die cast aluminum housing with power coated finish and having Ingress Protection up to IP-68. The LED is properly fitted on the arm of the pole and connected to the copper wire as provided	Job	3	9,486.00	28,458.00
3	In the high mast pole Providing and installation of Junction Box with DP 32Amp MCB to serve as amin switch for LED	job	1	2,227.00	2,227.00
9	lighting including complete wiring min 20-30 m from panel board.  Providing, Installation and testing of 2KVA fully automatic voltage stabilizer with input voltage 70-240 V and output 220 V. The stabilizer shall be installed and connected to the electric circuit	Job	1	8,154.00	8,154.00
)	as per location provided by site in charge.  Providing & fitting of lighting points for (machine room, operators room,) as per site requirement in 1.5 mm² multistranded single core 1100 volts, pvc insulated copper conductor through pvc conduit pipe by way, switches, socket modules, regulators, indicators, 08/10 watt LED lamps Surface light Make. Included is cost on account of modular switch boards with the wooden frames as per site requirements	Job	10	1,680.00	16,800.00
ı	Providing fitting of heating points in 2.5mm <sup>2</sup> multistranded single core 1100 volts, pvc insulated copper conductor through pvc conduit by way of p / f of 15 Amp switches, 6 pin socket on modular fitting as per site requirements. Heating points are to be connected from main control panel. All accessories required is to be provided by the firm	Job	2	1,470.00	2,940.00
2	Providing and fitting of 9" x 9"exhaust fan with complete wiring in 1.5 mm cu wire through conduit and 6 A modular control complete job. Make Providing and fitting of 9" x 9"exhaust fan with complete wiring in 1.5 mm cu wire through conduit and 6 A modular control complete job.	dot	1	2,625.00	2,625.00
	Providing, fitting of Distribution Board of reputed make 4 way S P N single door powder coated sheet steel enclosure for surface mounting fitted with bus bar, DIN channel, neutral link and incoming contact. the above DB is to be provided /fitted with double pole 40 amp MCB for Main. 32 A for heating circuit & rest 3 of 16/6 amps each for premises luminary, auxiliary circuit of reputed make. Further job includes providing / fitting 4 mm² multistranded single core 1100 volts, pvc insulated copper conductor through pvc conduit as service line from main panel as per site requirements. Connections should be made in such a way Lighting points is to be connected via automatic transformer by way of p/f switch socket arrangement with allied fixtures & and heating points to main panel. Job includes dismantling of existing damaged conduit, wires, conduit and cleaning the surface properly	Job	1	5,775.00	5,775

,					
44	Earthing of Panel boad, stabilizer, Motors, heating points, lighting points, D.G sets, electric substation, comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.  Safe earthing electrode size : 65/80 mm dia (As specified),  Length : 2000 mm  Back fill compound : 30 kg	Job	2	10,462.00	20,924.00
45	Painting on steel structure/pipe with synthetic enamel paint/emulsion of approved brand and maufacturer of required colour to give an even shade on new work( Two or more coats) including a coat of approved steel/cement primer but excluding a coat of mordant solution. (ref 13.61) schedule2021	sqm	50	147.00	7,350.00
46	Fabrication, providing, fitting of base frame for pumping units, covering of holes, fabrication of gantry, ladder, DG set covering, HT/Lt transformer Bed with gantry fabricated out of ISMC/ISMB/ISA/Bars/MS Pipe/MS plain-chequired Sheets. Including making of holes in concrete, including metal primer 1 coat and two coats of approved shade all complete welded. The works is to be executed as per site requirement and as per dimentions of Pumping unit and as per directions of site engineer.  Job Includes fabrication of Structural steel in built up sections, trusses and framed work, including cutting, hoisting, fixing in position.	kgs	1200	135.00	1,62,000.00
47	Providing and laying in position cement concrete of specified grade including curing but excluding the cost of centring and shuttering. All work upto plinth level 1:2:4 with stone aggregrate 20 mm nominal size. For DG Set foundation /concrete beds for rising-main as per requirement	cum	2	6,756.00	13,512.00
48	Centering and shuttering including strutting, propping etc and removal of form work for	sqm	1	303.00	303.00
49	foundation, footing, base  Earth work in excavation by manual means in trenches for foundations, drains, pipes, cables etc (Not exceeding 1.5 m in width) and ramming of bottoms lift 1.5 m, including getting out excavated earth and disposal of surplus exacavated earth as directed (All kinds of soil) (2.81 schedule)	cum	10	291.00	2,910.00
50	Providing and laying of soling stone	cum	5	713.00	3,565.00
51	Cement plaster in find sand in 1:3 mix finished with a coat of neat cement and curing complete 18 mm thick. (s-11.8)	sqm	3	588.00	1,764.00
52	Supply, installation, Testing & commissioning of 1000VA Full Sine wave power inverter including Providing / Installation of 12V, 180AH Tubular inverter Battery with trolley and cover. with 2-core 4 mm2 Cu (25 m) wiring as per site requirement along with other accessories like SS-Combine (02 No's), 3-pin plugs etc of reputed make for proper fitment and installation of the litem.	job	1	34,053.00	34,053.00
53	Providing, laying & fixing of shock proof rubber mats with adhesive/bonding material on the floor of the pump house, covering area around electro-mechanical machinery for safeguarding the life & limb of the workmen due to possible leakage of current & short circuit. The floor surface shall be made good & shall be free from dust, grease, foreign material & moisture free. The mats shall be as per IS 15652:2006 & shall have the following specifications: - Composition: Rubber (synthetic mats for electrical purpose) Thickness: - 2.5mm Size: - 1M wide. The rubber mats shall be accepted with manufacturers test certificate.	М	6	1,205.00	7,230.00
4	TOOL KIT For Maintenance: The Tool Kit for maintenance shall comprise of the following and all the items as mentioned below shall be of: Providing of tool kit consists of following items i.Double ended Spanner (Chrome plated) 02 sets complete iii.Double ended Ring spanners chrome plated 02 sets complete iii.Allen key set black finish 02 sets complete iii.Allen key set black finish 02 sets complete iv.Combination Pliers insulated with thick C.A sleeve; size in mm 165, 210, 255 each – 02 No. v.Long nose plier insulated with thick C.A sleeve; size in mm 165, 205 each – 02 No. vi.Side cutting plier insulated with thick C.A sleeve; size in mm 165, 205 make – 02 No. vi.Insulated screw Drivers Blade length in mm /Blade dia. in mm /Tip dimensions in mm / Quantity 50 3 1.6 x 0.4 02 10 3 3 x 0.4 02 11 3.5 3.5 x 0.5 02 12 3.5 3.5 x 0.5 02 13 3.5 x 0.5 02 14 4 x 0.6 02 15 5 x 0.8 02	Job	1	28,840.00	28,840.00



	i) Mattress with warm cover size 6'x3' (6Kg)- 02 No's ii) Quilt with warm cover size 5'x8' (6Kg)- 02 No's				
55	iii) Pillows with covers - 02 No's iv) Single bed warm blankets with one sided Fur- 02 No's The filling material for mattress, quilt and pillow shall be of good quality cotton b)The job also includes providing of pressure cooker 5ltr 02 No's, Steel patella (utensil) 5ltrs 02 No's, cooking heater 01 No., room heater 01 No., steel buckets 10 litre capacity 01 No., Plastic bucket 10 litre capacity with Mug 02 No's each, steel glasses 06 No's, steel Plates with large spoons and bowls 03 No's each, Cup and Saucer set (01 No. Set) and, 5kg Gas cylinder with burner/ stove. The job also includes providing of thermo-cool 15'x12' along with excel matting of 15'x12' size. The job also includes providing of unbreakable Plastic Chair table set consisting of chairs 04 No's, extra heavy Table 01 No. The job also includes providing of good quality safety Door locks (03 No's) of Godrej, Link locks,	Job	1	39,619.00	39,619,00
56	Providing and fitting of 01 No. angle Iron/sheet metal board duly painted showing various specifications of the mechanical and electrical equipments installed at site. The legs are to be grouted in cement concrete.	sft	24	209.00	5,016.00
57	Providing corrugated G.S Sheet roofing including vertical/ curved surface fixed with polymer coated J or L Hooks, bolts and nuts 8 mm dia. diameter with bitumen and G.I limpet washers filled with white lead, including a coat of approved steel primer and two coats of approved paint on overlapping of sheets complete (upto any pitch in horizontal /vertical or curved surface) excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required.  1.25 mm thick with zinc coating not less than 350 gram/m2	Sqm	3	1,799.00	5,397.00
58	Fabrication of 6' x 6' angle iron bed by way of providing and fitting of Structural steel in built up sections, trusses and framed work, including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer all complete welded	Kg	94.75	114.00	10,801.50
59	Providing and fitting of 19 mm thick multilayered ply sheet of size 6 x 3 feet , 2 no's including cutting , fixing all complete including painting of the play sheet by one coat of primer and two coats of enamel paint	sft	36	150.00	5,400.0
60	Providing of solar/ electrical lantern chargeable on both solar & electrical 220v supply.	Job	1	1,911.00	1,911.0
61	Providing of bamboo ladder 18 feet long with 15 feet long link rods and HT gloves pair (01 each)	Job	1	7,350.00	7,350.0
62	Providing of 1 KW heat convector for operators for winter season.	Job	1	1,205.00	1,205.0
63	Providing and fitting of 01 No. LED (scroll type) sign board fabricated out of stainless steel and metal showing the names of water supply scheme and the Department.  Size: 6'×1'6" = 9 Sft	Sft	9	3,998.00	35,982.0
64	Providing and fitting of 01 No. angle iron/sheet metal board duly painted showing various specifications of the mechanical and electrical equipments installed at site. The legs are to be grouted in cement concrete.	sft	24	209.00	5,016.0
65	Providing corrugated G.S Sheet roofing including vertical/ curved surface fixed with polymer coated J or L Hooks, bolts and nuts for DG Set and overhead gantry with bitumen and G.I limpet washers filled with white lead, including a coat of approved steel primer and two coats of approved paint on overlapping of sheets complete (upto any pitch in horizontal /vertical or curved surface) excluding the cost of purlins, rafters and trusses and including cutting to size	Sqm	3	1,799.00	5,397.0
	and shape wherever required.  1.25 mm thick with zinc coating not less than 350 gram/m2				

Executive Engineer