



Government of Jammu and Kashmir (UT)  
OFFICE OF THE EXECUTIVE ENGINEER  
JAL SHAKTI (PHE) MECHANICAL DIVISION SOUTH AWANTIPORA.  
E-MAIL ID: xenphemechsouthawp@gmail.com Fax/phone. 01933-295537



Allotment Order No: 71 of 08/2023

M/S M. Ashraf & Brothers  
Prop: Mohammad Ashraf Mala  
R/o: Turku Tachloo Anantnag  
GST No: 01ALTPM9214C1Z9  
e-mail: mabrothers2011@gmail.com  
Cell No: 9419043559/9858873856

AA Accorded vide Order No.	SE/Hyd/Ang/09 Dated: 05/05/2021
Tech. Sanction Accorded vide Order No.	EE/JSD/Mech/ Awp/JJM/07 of 08/2022
Adv. Cost:	Rs. 12,10,000/-
Allotted Cost:	Rs. 12,10,000/-

Subject:- Supply, installation, testing and commissioning of electro-mechanical equipments at water supply scheme Turku Tachloo of Jal Shakti (PHE) Mechanical Division South Awantipora under JJM.

Reference:- 1. This office e-NIT No.: 06 of 2023-24 of 02/05/2023 issued under endorsement No.: JSD/PHE/MDSA/294-306 Dated: 01/05/2023 read with Corrigendum No.: JSD/PHE/MDSA/505-07 Dated: 13/05/2023.  
2. Superintending Engineer PHE Mechanical Circle (South) Srinagar's Authorization No.: JSMCS/TS/1258-60 Dated: 27/07/2023.  
3. Acceptance of rates confirmed by you.

\*\*\*\*\*

Dear Sir,

For and on behalf of Lt. Governor of J&K U.T contract for execution of aforementioned job is hereby fixed with you on percentage basis. This is in response to your online bid and subsequent acceptance of rates, specifications, terms and conditions as contained in Annexure "A & B" of this allotment order.

Encl. 09 Ltr.

No.: MDSA/ 2344-51

Dated: 01 /08/2023

Yours Sincerely

Executive Engineer  
Jal Shakti PHE Mechanical Division  
(South) Awantipora  
(Member JJM)

Copy to the:

1. Chief Engineer Jal Shakti (PHE) Department Srinagar for information.
2. District Development Commissioner (Chairman DJJM) Kulgam for information.
3. Superintending Engineer Jal Shakti (PHE) Mechanical Circle (South) Srinagar for information. This is with reference to his No. under reference at Sl. (02) above.
4. Superintending Engineer Jal Shakti (PHE) Hydraulic Circle Anantnag/Kulgam for information.
5. Executive Engineer Jal Shakti (PHE) Division Kulgam for information & n/a.
6. Provisional Head, TPIA JJM Kashmir, (WAPCOS Limited) Corporate Office 76-C Institutional area Sector-18 Gurugram-122015 (Haryana) for information.
- ✓ 7. Assistant Executive Engineer Jal Shakti (PHE) Mech. Sub Division Qazigund for information & necessary action. He will ensure execution of work strictly in accordance with the rates, specifications, terms / conditions & within the stipulated time, besides, the cost of work should not exceed beyond allotted cost. In case of any delay in completion of work, the reasons shall be justified.
8. File concerned.



Name of work: Supply, installation, testing and commissioning of electro-mechanical equipments at water supply scheme Turku Tachloo of Jal Shakti (PHE) Mechanical Division South Awantipora under JJM.

General Terms and Conditions: -

1. **TIME OF COMPLETION:** The scheme shall have to be completed/tested/commissioned within a period of 45 days from the date of issue of this allotment order.
2. **AGREEMENT:** A formal agreement deed shall be executed by the firm with the department within a period of 07 days from the date of issue of this allotment order after deposition of performance security @ 03% of allotted cost. However, non drawl of agreement will not prevent the contract from being enforced upon you.
3. **PENALTY:** In the event the contractor failing or delaying the work or a part thereof, & or non-complying with any of the terms and conditions of the contract, the NIT & the Agreement, the Department, without prejudice to the remedies available under the law in force in J&K UT, may terminate the contract after seven days' notice, and or recover the amount of loss caused by failure/delay or default of the contractor. The amount of such recoveries shall be determined by the Superintending Engineer PHE Mechanical Circle South Srinagar and or impose a penalty as the Government /Department may determine and or forfeit the performance security and or resort to any or all the remedial actions available under the law in force in the UT of J&K at the time of the dispute.
4. **ARBITRATION:** In case of any dispute arising at any stage between the contractor and the Department, the same shall be referred to the Superintending Engineer PHE Mechanical Circle South Srinagar /Govt. of J&K who may give a decision or nominate any other person of Government for arbitration. The decision to such arbitration shall be final and binding on both the parties.
5. **PERFORMANCE SECURITY DEPOSIT:** Soon after issuance of allotment order, the firm has to deposit performance security in the shape of CDR/FDR/BG valid for 18 months pledged to Executive Engineer PHE Mechanical Division (South) Awantipora within 07 days which shall be released after expiry of defect liability period/report of concerned AEE (After fulfillment of all contractual obligations). Failing to produce performance security, the firm is liable to be debarred for participation in future tendering in this Division and same shall be recommended to higher offices and other Govt. offices of UT of J&K.
6. **JURISDICTION OF COURT:** All disputes pertaining to this contract shall be subject to the jurisdiction of the Courts of J&K UT only.
7. **TERMINATION OF CONTRACT:** The department reserves the right to terminate the contract at any stage in case performance of the firm is found un-satisfactory in terms of any or all clauses of the NIT/Contract/Agreement in vogue.
8. **ADVANCE PAYMENT:** The Department shall in no case entertain any condition or request of making advance payment of any kind to the contractor during the execution of the work.
9. **TAXES, DUTIES LEVIES etc.:-** The rates offered by the Department shall be firm and final. Payment of Income Tax/GST, Octroi, Toll tax, Entry tax, Cess service tax duties and other levies etc. of the central or the UT Government and incidental charges of any shall be the responsibility of the contractor/firm.
10. **FORCE MAJEURE CLAUSE:** Any failure or omission to carrying out the provision of the contract shall not give rise to any claim by the department or the contract one against the other if such failure or omission arises from the Act of God which shall include all natural calamities such as fire, floods, earthquakes, hurricane strikes, riots, embargoes from any political or other reasons beyond the control of parties including the war whether declared or not civil war or a state of insurrection.
11. **ENGAGEMENT OF LABOURS:** The contractor shall not engage any workman below the age of 18 years. Firm/Contractor shall also comply with the provisions of labour laws and rules framed thereof and as prevalent in the UT of J&K. The contractor shall be responsible for any accident to the human life which may occur during the execution of work, compensation as shall be provided under law or any law will be payable by the contractor.
12. **INSURANCE:** The contractor shall insure all work-man at his own cost till the completion of work and take over by the department.
13. **DEFECT LIABILITY PERIOD:-** The defect Liability period shall be for a period of 12 Months which shall commence after the successful completion of Trial run, during the defects Liability period (DLP) the firm shall have to operate & maintain the scheme as it is required for its successful running & as per Standard Engineering Practices, to the full satisfaction of the department. The bidder shall be responsible to make good & remedy at

(Contd. On page...2<sup>nd</sup> ...)

Executive Engineer



his own expense any defect in works which is noticed during the DLP. In case any defect remains unattended by the firm at the completion of DLP, the department may extend the DLP for such time as deemed fit for getting the defect rectified subject to a maximum ceiling of 6 Months.

14. **TRANSIT INSURANCE:-** Prior to dispatch, the ordered equipment shall be insured through a Nationalized Insurance Company up to its final destination, against all transit risks. The firm should, therefore, take appropriate insurance policy in advance for covering the transit of the goods, charges for which shall be borne by the tenderer and shall be included in his quoted rates. The department shall pay no extra charges on this account.
15. **SUBLETTING OF WORK:-** The bidder shall not sublet the whole or part of the work. The bidder shall not assign the work or any part thereof or any benefit or any interest thereon or any claim arising of the contract, without prior written consent of the allotting authority.
16. **LIQUIDATED DAMAGES (LD):-** In the event of firm's/joint venture failing, declining, neglecting or delaying the supplies / works or in the event of any damage occurring or being caused by the firm/ joint venture or in the event of any default or failure by the firm in complying with any of the terms and conditions of the contract, the Department shall with or without prejudice to any other remedies available to it under any law for the time being enforce in the UT:
  - a) Terminate the contract after 15 days' notice  
and/or
  - b) Recover the amount of loss caused by damage, failure or default, as may be determined by the department.  
and/or
  - c) Recover the extra cost, if any, involved in allotting contract to other party.  
and/or
  - d) Impose Liquidated damages on account of delay beyond the schedule completion period to the tune of 0.5% of the delayed portion of contract every week but not exceeding 10% value of the contract.  
and/or
  - e) Forfeit the performance security and blacklist the firm.
17. **THIRD PARTY MONITORING:** The allotted works shall be subject to check by the third party monitoring agency appointed by the Department in Kashmir. The agency shall check the quality of works executed by the agencies, quality of materials used for construction and quality of machinery installed in each scheme. The TPIQM's role shall be that of an assistant to the Employer's Representative for the purpose of monitoring and evaluation of the performance of the Contract during the Contract Period.
18. **STORAGE AT SITE:** The bidder shall at his own cost make arrangements for proper storage especially towards Rain and Snow damages of the equipment/ materials at sites till its erection/completion. For the purpose the bidder shall, with the approval of Engineer in charge construct temporary storage accommodation for equipment/ material at site for which land shall be provided by the department near the site of work.
19. **OPERATION AND MAINTENANCE MANUALS:** The bidder shall supply, free of cost to the Department, six complete sets of operation and maintenance manuals for the Pumping Equipment. The delivery of these manuals shall be made by the bidder to the Engineer along with the supply of equipment. The manuals shall be appropriately bound in book form and shall contain all necessary instructions regarding operation, preventive maintenance, repairs, trouble shooting, overhauling etc.
20. **OEM Certificate:** The contractor shall produce all relevant test certificates of the manufacturer to the Engineer in-charge before start of the work. The test certificates of the equipment's on whole or all accessories/ attachments and mountings thereof shall be appended with the invoice at the time of submission of the claim to Divisional office. Failure to do so shall result in non-acceptance of invoice/bills by the Divisional office.
21. **CLARIFICATION:** If any clarification is required by the Firm/contractor in relation of technical specifications, the same shall be had from the office of the Assistant Executive Engineer concerned/ Executive Engineer PHE Mechanical Division South Awantipora before the date of start of work.

(Contd. On page...3<sup>rd</sup> ...)

Executive Engineer




ANNEXURE "A" to this office Allotment Order No: 71 of 08/2023

**31. INSPECTION & TESTING:-** Before dispatch from the works of the OEM, the electro-mechanical equipment shall be inspected by a third party inspection agency i.e. M/S CEIL/Rites/WAPCOS etc. New Delhi. However, the Firm (Bidder) shall make payment to the Inspection Agency (in case of 3<sup>rd</sup> Party Inspection) which shall subsequently be reimbursed by the Department. The successful tenderer shall intimate the Department and the Inspecting Agency/Authority in advance regarding the readiness of the equipment for dispatch and shall furnish test certificates. It shall be responsibility of the suppliers to tie up with the third party nominated for inspection and get necessary inspection of the material done within the delivery period. Any delay on the part of the third party shall not be entertained as an excuse for timely supply of material. The product/ material at site shall be inspected by Assistant Executive Engineer concerned or any other official(s) of the department designated by the concerned Executive Engineer. Any modifications to the works as specified in the specifications considered to be necessary for smooth and trouble-free operation of the equipment by the Department or the third-party inspection agency, the firm shall have to execute the same without any extra cost, to the best satisfaction of the department. The firm shall as such keep the department informed about arrival of material at site. It shall be obligatory on the part of the firm to rectify the defects pointed out by the AEE, if any, and also to incorporate any modification within the scope of work which may be deemed necessary for better performance/finish and workmanship. The supplier upon demand by the department or its representative shall rectify or replace defective unsuitable equipment. The Department reserves the right to nominate his representative for inspection of the goods at the works of the supplier/ manufacturers. As such the department at all reasonable times shall have access to the works and to the site and to all workshops and places where work is being executed and where material / manufactured articles and machinery are being obtained. In case of Sub-Station and power/feeder lines, the firm shall have to obtain a clearance certificate from the concerned inspection Division of the Power Development Department. The list of electromechanical equipment in which third party inspection from CEIL/RITES/WAPCOS is to be carried on:-

- 1) DG Set > 100 KVA.
- 2) Pumping Unit > 100 HP (Horizontal and Vertical)
- 3) Valves >300 mm
- 4) Pipe > 200mm dia
- 5) HT Transformers > 300 KVA
- 6) Voltage Stabilizers > 500 KVA
- 7) Iron Removal Plant



For items other than those manufacturers test certificate shall have to be provided. The HT transformers shall have to be got inspected from the corresponding wing of Power Development department and the necessary certificate shall be submitted along with the manufacturers test certificate.

32. The work is executed strictly in close supervision of AEE/JE/Supervisory staff concerned. However, the civil work if involved should be executed under close supervision of civil counterpart.
33. **WATCH & WARD OF WORKS:** The Firm shall in connection with the work provide and maintain at his own cost all lights, guards, fencing and watching, when and where necessary or required by the Department for the protection of the work or safety and convenience of the Public etc.
34. All other terms and conditions shall be the part of this contract as laid down in e-NIT/SBD/GFR-2017/e-procurement manual 2019 and PWD form "25" double.

  
Executive Engineer  
Shakti PHE Mechanical Division  
(South) Awantipora  
(Member JJM)

**Annexure 'B' to this Office Allotment Order No. 71 of 08/2023 for WSS Turku Tachloo under JJM**

SI.No	Description of Work / Item(s) with Technical Specifications	No. of Qty	Units	Alloted/ Accepted Rate	Amount
1	<b>Electro Mechanical items of WSS Turku Tachloo</b>				
2	<p>Supply, Installation, Testing &amp; Commissioning of Submersible Horizontal monoset Pumping Unit for raw water of river as per IS 8034 with following specification are as under :</p> <p><b>PUMP : Discharge: 10000 GPH</b>      <b>Head: 19 Mts</b>                      Efficiency = Not less than 50%      Speed = 2900 Rpm                      Type of pump = Mixed flow.      Type of fluid to be handled = Clear Water</p> <p><b>MATERIAL OF CONSTRUCTION:</b>                      Impeller = Stainless Steel      Pump Shaft = Stainless Steel SS 410                      Pump Casing = Cast Iron/Stainless steel</p> <p><b>IMPELLER:</b> Impeller is of the enclosed or semi – enclosed type and properly balanced. Enclosed Impellers equipped with seal rings on their hubs.  <b>COUPLING:</b> A suitable coupling arrangement provided with pump set.                      Non Return Valve: - Non Return Valve of the suitable size provided above the pump discharge case.</p> <p><b>MOTOR - Rating = 5 HP</b>                      Method of starting = Star – Delta      Speed = 3000 (Sync).                      Frequency = 50 ± 3 % Hz      Working Voltage = 380-415 ± 15% V, 03 phase                      Efficiency = Not less than 90%      Class of insulation = F</p> <p>Submersible motor should be water filled water lubricated squirrel cage type having capacity for above pumping parameters and working on 3 phase, AC supply ranging from 380 to 415 volts, 50Hz. The motor should be sealed by radial rings to avoid mixing of well water with motor filled water.</p> <p>a) The job includes providing and fitting of interlocking arrangement against any failure of coupling. It must be fabricated out of MS strips of suitable size and length.                      b) The job includes providing and fitting of appropriate size MS nipple 2 feet long threaded on one end and welded to same size MS flange of thickness (as per Table-17) at other end for 80 mm dia column pipe as per site requirement. The threaded portion should be as per size of pumping out let for proper fixing.                      The job includes providing and fitting of R. I. cloth joints/rubber washers with nuts, bolts and washers for all joints of column pipe. The job also includes lowering of pumping unit in the well then proper testing and commissioning of pumping unit on full load at site.                      Note: Providing of test certificate &amp; Characteristic Curve of pumping equipment is compulsory and pumping unit is to be approved from the concerned Sub Divisional office before procuring.                      (Make: KSB/Kirloskar/Mather Plate)</p>	2.000	Job	35631.000	71282.00
3	<p>Supply, Installation, Testing &amp; Commissioning of Submersible Horizontal monoset Pumping Unit for PST/Sump to liftwater through pressure filterplant upto OHT as per IS 8034 with following specification are as under :</p> <p><b>PUMP : Discharge: 10000 GPH</b>      <b>Head: 45 Mts</b>                      Efficiency = Not less than 50%      Speed = 2900 Rpm                      Type of pump = Mixed flow.      Type of fluid to be handled = Clear Water</p> <p><b>MATERIAL OF CONSTRUCTION:</b>                      Impeller = Stainless Steel      Pump Shaft = Stainless Steel SS 410.                      Pump Casing = Cast Iron/Stainless steel</p> <p><b>IMPELLER:</b> Impeller is of the enclosed or semi – enclosed type and properly balanced. Enclosed Impellers equipped with seal rings on their hubs.  <b>COUPLING:</b> A suitable coupling arrangement provided with pump set.                      Non Return Valve: - Non Return Valve of the suitable size provided above the pump discharge case.</p> <p><b>MOTOR:- Rating = 15 HP</b>                      Method of starting = Star – Delta      Speed = 3000 (Sync).                      Frequency = 50 ± 3 % Hz      Working Voltage = 380-415 ± 15% V, 03 phase                      Efficiency = Not less than 90%      Class of insulation = F</p> <p>Submersible motor should be water filled water lubricated squirrel cage type having capacity for above pumping parameters and working on 3 phase, AC supply ranging from 380 to 415 volts, 50Hz. The motor should be sealed by radial rings to avoid mixing of well water with motor filled water.</p> <p>a) The job includes providing and fitting of interlocking arrangement against any failure of coupling. It must be fabricated out of MS strips of suitable size and length.                      b) The job includes providing and fitting of appropriate size MS nipple 2 feet long threaded on one end and welded to same size MS flange of thickness (as per Table-17) at other end for 80 mm dia column pipe as per site requirement. The threaded portion should be as per size of pumping out let for proper fixing.                      The job includes providing and fitting of R. I. cloth joints/rubber washers with nuts, bolts and washers for all joints of column pipe. The job also includes lowering of pumping unit in the well then proper testing and commissioning of pumping unit on full load at site.                      Note: Providing of test certificate &amp; Characteristic Curve of pumping equipment is compulsory and pumping unit is to be approved from the concerned Sub Divisional office before procuring.                      (Make: KSB/Kirloskar/Mather Plate)</p>	1.000	Job	75000.000	75000.00
4	<p>Providing and fitting of Ductile Iron double flanged, non-rising spindle soft seated glandless gate/slucice valves as per IS14846 for regulating the water supply outside the pumping units .                      The body and bonnet of the valve shall be of ductile iron, wedge with fully vulcanized EPDM rubber (Approved for drinking water) and NBR seal. The Slucice valve shall be compatible for buried applications and shall be safe to install in both horizontal and vertical positions.                      It shall have electrostatic epoxy coating (approved for drinking water) both inside and outside of the valve. The valve shall be supplied along with hand wheel.                      Cost on account of Nuts, bolts, gaskets, etc required for the job is included in the scope of work.                      The job includes providing and fitting of 02 Nos. M.S flanges (Table flanges) perfectly adaptable to the inbuilt flanges of the valve which shall be fitted with rising main of the pumping unit at appropriate spots as per site requirement. The job includes the cost on account of P/F of nuts, bolts and gasket required for the job.                      Size: DN 100 PN:1.6/16 (Make: VAG/Tallis/Sigma Flow)</p>	1.000	Nos	18538.000	18538.00

  
 Executive Engineer  



Annexure 'B' to this Office Allotment Order No. 71 of 08/2023 for WSS Turku Tachloo under JIM

SI.No	Description of Work / Item(s) with Technical Specifications	No. of Qty	Units	Alloted/ Accepted Rate	Amount
5	<p>Providing and fitting of Ductile Iron double flanged, Slanted seat swing check valve (NRV) as per IS 5312. The body shall be of ductile cast iron with fully encapsulated vulcanized EPDM rubber (Approved for drinking water). The valve shall be compatible for buried applications and shall be safe to install in both horizontal and vertical positions.</p> <p>It shall have electrostatic epoxy coating (approved for drinking water) both inside and outside of the valve.</p> <p>Cost on account of Nuts, bolts, gaskets, etc required for the job is included in the scope of work.</p> <p>The job includes providing and fitting of 02 Nos. M.S flanges (Table 17 flanges) perfectly adaptable to the inbuilt flanges of the valve which shall be fitted with Rising main of the pumping unit at appropriate spots as per site requirement. The job includes the cost on account of P/F of nuts, bolts and gasket required for the job.</p> <p><b>Size: 100 mm PN: 1.6/16 (Make: VAG/Tallis/Sigma Flow)</b></p>	1 000	Job	19982 000	19982.00
6	<p>Fabrication, providing and fitting of 100 mm dia washout Tee/Y junction with arm length 1.2 feet each. The Tee shall be fabricated out of G I " C-class " pipe with M.S Flanges conforming to BIS 6392/1997 Table 17 (Rating PN16) fastened with weld joints on three ends.</p>	2 000	Job	8489 000	16978.00
7	<p>Fabrication, Providing and fitting of Modular motor control panel of appropriate size fabricated out of 14 SWG sheet having required openings/vents and protection Class : IP-55 &amp; fitted with accessories as under:</p> <p>a) Bus bar Chamber: The bus bar chamber shall be fitted at the top of the panel horizontally throughout the length. There shall be 3 Nos. of phase bus bar and 1 No neutral bus bar and 1 No earthing bus bar. The bus bars shall be air insulated and made-up of high conductivity COPPER with current density of suitable rating for 100 Ampere. All panel compartments shall be provided with suitable cable alley and vertical bus bar alley. Suitable segregation shall be provided in between bus bar chamber and adjoining compartments. The bus bar shall be PVC sleeved with color strips of red, yellow, blue and black and the same be arranged in accordance with IS-375 specs. Electrical clearances shall be maintained between phases, neutral and body as per standards.</p> <p>b) Main Circuit Breaker (Incomer MCCB): Qty. = 02 No. of poles = 4 Pole Current Rating = 100 Amp. Rated operational voltage = 415 V + 15 % Rated frequency = 50+/-3%Hz Ambient temperature = 40C Ultimate S.C Breaking Cap. at (415V AC, 50 Hz) = 36 KA Type of release = Thermal-Magnetic Release Range 80-100 amp Overload protection = 0.8 – 1×In adjustable Short-circuit protection = 6-10×In adjustable.</p> <p>c) Change over Switch: Qty. = 01 No. Rating = 100 Ampere Type = Front operated, on load, 4 pole, 400 +15%V, 50 + 3%Hz.</p> <p>d) Motor Back-up Protection MCCB: Qty = 2 Nos. No. of poles = 3 Pole Current Rating = 100 Amp Rated operational voltage = 415 V +15 % Rated frequency = 50 + 3% Hz Ambient temperature = 40C Ultimate S.C Breaking Cap. at (415V AC, 50 Hz) = 36 KA Thermal Release Range: 80-100 Amp</p> <p>a. Submersible starters:- Fully automatic submersible motor starters. b. Capacity = 10 HP Power Specs = 3 Φ, 415 + 15% V, 50 + 3 % Hz. Relay range = 13-21 A. Protection = Under voltage/over Voltage relays (01 No. for each starter) Reversal, phase unbalance (55 ± 5 V), Rated insulation voltage = 690V Terminal capacity = 120 Sq. mm with lug Or above Conformity to standard = IS/IES 60947-4-1 Qty. = 2 No's</p> <p>e) Auxiliary MCCB for Heating/Lighting: Circuit Breaker = MCCB (Outgoing) Qty. = 1 No. No. of poles = 4P Current Rating = 63 Amp Rated operational voltage = 415 V + 15 % Ultimate S.C Breaking Cap. at (415V AC, 50 Hz) = 25 KA</p> <p>g) Motor Protection Relay: <i>(L&amp;T) Rel.</i> Digital Motor Protection Relay with LCD Display for 3-phase supply with following protections suitable for the Modular Control Panel:- Protections = Thermal Overload with pre-alarm, Short Circuit, Phase Loss, Unbalance, Phase reversal, Under Current, over current, Prolong starting, Locked Rotor, &amp; Earth fault &amp; over current. (Qty. 03 No. 01 for each starter)</p> <p>h. M-power module for mobile starter for submersible motor 1P/3P 3 wire IVRS Languages – English , Hindi, Suitable Region- North India. (Qty.- 02 No.)</p> <p>f) The panel shall be provided with phase indicators (03 NO) and digital ammeter of range 0-60 A, digital voltmeter of range 0-500 V, and digital frequency meter (01 No for each starter). The enclosure of the panel shall be of excellent fit and finish, corrosion resistant and powder coated gliding hinges for smooth and noiseless movement of windows and advanced locking arrangements. <b>(Change Over/MCCB Make: L&amp;T/Havells/GM)</b></p>	2.000	Job	145001.000	290002.000

Executive Engineer

Annexure 'B' to this Office Allotment Order No. 71 of 08/2023 for WSS Turku Tachloo under JJM


Sl.No	Description of Work / Item(s) with Technical Specifications	No. of Qty	Units	Alloted/ Accepted Rate	Amount
8	<p>Providing, fitting, testing and commissioning of 50 KVA voltage stabilizer as per specifications below:                      Type of voltage controller: Manually operated copper wound, 3-phase, AC power supply multi step                      Type of Regulator: Double plate type with electrolytic copper contacts                      Input voltage: 170-400 volts (3 phase)                      Output voltage: 400 ±10% volts                      Frequency: 50 ±3 C/S                      Windings: Electrolytic grade copper of adequate section, vacuum impregnated and Oven-dried                      Insulation: Fiber glass insulations to tested parameters                      Cooling: Naturally, Oil cooled                      Temp. Rise (Max): 30°C above ambient                      Mounting: On Uni-directional wheels.                      Correction rate: 30 volts per step                      Wave form distortion: virtually nil                      Duty cycle: 100% continuous                      Enclosure: MS sheet enclosure in pressed CGR Sheet powder coated with radiators.                      Core laminates: High grade, low eddy loss, grain oriented silicon steel laminations.                      Load: Three phase induction motor load.                      Load Amperes (continuous)                      Overload in 24-hours operation: 10% above continuous Ampere rating.                      The voltage stabilizer shall have T-oil level indicator gauge preferably glass type tube or otherwise visible to naked eye. The top of the container to have a display panel for housing 02 numbers Digital voltmeters (0-500V) along with 4-way selector switch and set of neon indicators for incoming and outgoing phases (06 No's).                      Insulating media (T. Oil) of 11 KVA grade to be provided and filled up to top level, with dielectric strength of 5 KV at 4m air gap. The T-Oil of specific grade should be provided in separate barrels and filled at site up to top level.                      The voltage Stabilizer shall be accepted with manufacturers dully stamped test certificate and shall have name plate with specifications.</p>	1.000	Job	97637.000	97637.00
9	<p>Providing and fitting of 3-Core flat 10 sq.mm submersible copper cable conforming to IS: 694 (Part 1st) - 1964 &amp; IS: 694 (Part 2nd) - 1964 for Submersible Pumping Unit and other electrical Equipments. The cable connections terminal shall be fitted with copper thimbles of required size. (Make: Havells/Polycab)</p>	100.000	Mtr	454.000	45400.00
10	<p>P/I of earthing station for 63 KVA electric substation, LT panel and stabilizer comprising of company fabricated earthing electrode as per IS: 3043. The job includes Auguring of bore of required dia/depth for installation of electrode along with backfill compound mixed with soil and all other items required thereof for achieving the best result. The job includes connecting of electric gadgets through GI strip as per relevant standards.                      Safe earthing electrode size: 80 mm dia,                      Length: 2000 mm                      Back fill compound: 30 kg</p>	4.000	Nos	10462.000	41848.00
11	<p>Supply, installation, Testing &amp; commissioning of 1000VA Full Sine wave power inverter (Make: Luminious/Exide) including Providing / Installation of 12V, 180AH Tubular inverter Battery with trolley and cover. (Make: Luminious/Exide/Amaron) with 2-core 6mm<sup>2</sup> Cu wiring as per site requirement along with other accessories like SS-Combine (02 No's), 3-pin plugs etc of reputed make for proper fitment and installation of the item.</p>	1.000	Job	34053.000	34053.00
12	<p><b>TOOL KIT For Maintenance: -</b>                      The Tool Kit for maintenance shall comprise of the following and all the items as mentioned below shall be of Providing of tool kit consists of following items                      i. Double ended Spanner (Chrome plated) 02 sets complete of size in mm.                      6/7, 8/9, 10/11, 12/13, 14/15, 16/17, 18/19, 20/21, 22/23, 24/25, 26/28, 24/27, 30/32.                      ii. Double ended Ring spanners chrome plated 02 sets complete of size in mm.                      6/7, 8/9, 10/11, 12/13, 14/15, 16/17, 18/19, 20/21, 22/23, 24/25, 26/28, 24/27, 30/32.                      iii. Allen key set black finish 02 sets complete of size in mm. 1.5, 2, 2.5, 3, 4, 5, 6, 8, 10.                      iv. Combination Pliers insulated with thick C.A sleeve; size in mm 165, 210, 255 each - 02 No.                      v. Long nose plier insulated with thick C.A sleeve; size in mm 165, 205 each - 02 No.                      vi. Side cutting plier insulated with thick C.A sleeve; size in mm 165, 205 make - 02 No.                      vii. Insulated screw Drivers                      Blade length in mm Blade dia. in mm Tip dimensions in mm Quantity                      50 3 1.6 x 0.4 02                      75 3 1.6 x 0.4 02                      100 3 3 x 0.4 02                      125 3 5 3.5 x 0.5 02                      150 3 5 3.5 x 0.5 02                      200 4 4 x 0.6 02                      300 5 5 x 0.8 02                      viii. Hammer with handle weight - 110 gm, 340 gm, 600 gm - each - 1 No. .                      ix. Heavy duty pipe Wrench length in mm - 200, 300, 600 each = 01 No.                      x. Electric Multimeter=1No                      xi. Digital multimeter - 1No.                      xii. Digital Clamp tester capable to measure up to 400A - 1 No.                      xiii. Hack saw frame with hack saw blade - 01 no.                      xiv. S-16 MXL, S- 16 H X L Socket Set (19 sockets + 6 Accessories) - 01 No.</p>	1.000	Job	28840.000	28840.00
13	<p>Fabrication of 6' x 6' angle iron bed by way of providing and fitting of Structural steel in built up sections, trusses and framed work, including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer all complete welded.</p>	94.750	Kg	89.000	8811.75
14	<p>Providing and fitting of 19 mm thick multilayered ply sheet of size 6 x 3 feet, 2 Nos. including cutting, fixing all complete including painting of the play sheet by one coat of primer and two coats of enamel paint</p>	36.000	Job	140.000	5040.00

Executive Engineer  




Annexure 'B' to this Office Allotment Order No. 71 of 08/2023 for WSS Turku Tachloo under JJM

Sl.No	Description of Work / Item(s) with Technical Specifications	No. of Qty	Units	Alloted/ Accepted Rate	Amount
15	a) Providing of good quality bedding for night stay/Shift consisting of - i) Mattress with warm cover size 6'x3' (6Kg)- 02 No's ii) Quilt with warm cover size 5'x8' (6Kg)- 02 No's iii) Pillows with covers - 02 No's iv) Single bed warm blankets with one sided Fur- 02 No's The filling material for mattress, quilt and pillow shall be of good quality cotton b) The job also includes providing of pressure cooker 5ltr 02 No's, Steel patella(utensil) 5ltrs 02 No's, cooking heater 01 No, room heater 01 No, steel buckets 10 litre capacity 01 No, Plastic bucket 10 litre capacity with Mug 02 No's each, steel glasses 06 No's, steel Plates with large spoons and bowls 03 No's each, Cup and Saucer set (01 No Set) and 5kg Gas cylinder with burner/ stove The job also includes providing of thermo-cool 15'x12' along with excel matting of 15'x12' size The job also includes providing of unbreakable Plastic Chair table set consisting of chairs 04 No's, extra heavy Table 01 No The job also includes providing of good quality safety Door locks (03 No's) of Godrej, Link locks	1 000	Job	39619 000	39619.00
16	Providing & Fitting of lighting points in 1 50 mm Sq multi strand PVC wire as conductor to be laid/carried in PVC channel /conduit as per site requirement The Job also includes Providing and fitting of 5 Amp. Switch Button /angle holders to be fitted with 15 watt LED inside the Pump house	6 000	Job	1200 000	7200.00
17	Providing & fitting of heating points in 2.5 sq multi stand conductor to be laid & carried in PVC channel/Conduit as per site requirement The job includes providing and fitting of 16 Amp. Switch socket combine	4.000	Job	1500 000	6000.00
18	Providing and fitting of 18" sweep selling fan of standard make including the cost of all cables, connections, control system along with the speed regulator with control switches for the power supply.	2.000	Job	4500 000	9000.00
19	Providing of solar/ electrical lantern chargeable on both solar & electrical 220v supply.	1.000	Job	1900 000	1900.00
20	Providing of bamboo ladders 18 feet long along with 15 feet long Link rods and HT Glove pair (01 No each).	1.000	Job	7350 000	7350.00
21	Providing of 1 KW heat convector for operators for winter season.	1.000	Job	1205 000	1205.00
22	Providing and fitting of 01 No LED (scroll type) sign board fabricated out of stainless steel and metal showing the names of water supply scheme and the Department.Size: 6'x1'6"	9.000	Sft	3998.000	35982.00
23	Providing and fitting of 01 No. angle iron/sheet metal board duly painted showing various specifications of the mechanical and electrical equipments installed at site. Size: 4'x6' out MS ANGLE OF 40X 40X 5 of 36 rft and MS sheet of 1 mm thick total weight of 50.16 kgs	24.000	Sft	250.000	6000.00
24	Illumination of Premises: Providing and erection of 9 Mtr long Hot Dip Galvanized octagonal pole (single Section) with bottom 150mm, top 75mm wide, thickness 3mm with 70 Microns Zinc coating having inside arrangement for providing of power connection along with following items. 1) 3 Way Terminal Connector 20 Amp. 2) 3 No MCB 8 Amp. The job includes fabrication, providing and fitting of three arm GI structure at the top having 120° angle between arms and each arm having 15° inclination with respect to horizontal plane. Each arm should be of 2' length and size and shape appropriate as per requirement of the luminary. The job also includes providing and fitting of required length of flexible multistrand 2 mm copper wire from each terminal connector to each holding arm. The pole is mounted on 1:2:4 Cement concreting of size not less than 2'x2'x6" (cost of concreting not included in the job) using 04 No anchor bolts of required size not less than 7" in length. The complete job includes earthing in GI Electrode as per relevant IS Code.	1.000	Job	21168.000	21168.00
25	Providing, installation, testing and commissioning of area lighting 120 Watt LED (Street Light Type) on top of octagonal pole. Having following specs: (Make: Havells/Bajaj/Phillips). Input: 90-240 V 50 Hz Power Factor: >0.9 Colour Temperature: 4K - 6.5K Beam Angle: 120° - 170° Lumens: >12000 Operating Temperature: -20°C to 60°C The LED is pressure die cast aluminum housing with power coated finish and having Ingress Protection up to IP-68. The LED is properly fitted on the arm of the pole and connected to the copper wire as provided in the high mast pole	3.000	Job	8866.000	26598.00
26	Fabrication of gantry mechanism by way of providing Structural steel in built up sections, trusses and framed work, including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer all complete welded.	647.000	Kg	102.000	65994.00
27	Earth work in excavation required for installation of Gantry mechanism and associated works by manual means in trenches for foundation, drains, pipes, cables (not exceeding 1.5 m in width) and for shafts, wells, cesspits and the like not exceeding 10 sqm on plan, including dressing of sides and reaming of bottom lift upto 1.5 m, including getting out excavated earth and disposal of surplus excavated earth as directed in all kinds of soil.	0.540	cum	479.000	258.66
28	Providing and laying of soling stone.	0.110	cum	679.000	74.69
29	Providing and laying in position cement concrete of specified grade including curing but excluding the cost of centring and shuttering. all work upto plinth level with 1: 2 : 4 (1 cement, 2 coarse sand, 4 graded stone aggregate 20 mm nominal size).	0.648	cum	6434.000	4169.23
30	Centering and shuttering including strutting, propping etc. and removal of form work for Foundation, footings, bases for columns.	1.440	Sqm	289.000	416.16
31	Painting of the 2 no. gantry and plate form of well using one coat of red oxide metal primer and two coats of enamel paint of different shades.	1.000	Job	3000.000	3000.00

Executive Engineer  
  
 10/08/2023

Annexure 'B' to this Office Allotment Order No. 71 of 08/2023 for WSS Turku Tachloo under JJM

Sl.No	Description of Work / Item(s) with Technical Specifications	No. of Qty	Units	Alloted/ Accepted Rate	Amount
32	<p>Providing, installation and testing of manual type triple spur gear chain pulley block along with monorail geared travelling trolley having following features</p> <p>Gears - The hoist shall have precision machine case Hardened alloy steel gear mounted on bearings and housed in a dust proof gear box. The lubrication of gears should be of high viscosity and temperature for longer life of gears.</p> <p>Load Chain - The load chain be made of high tensile alloy steel having wear resistance and greatest mobility. The chain should be accurately collaborated, tested and have adequate in built factor of safety for safer operation.</p> <p>Load chain wheel - the load chain well should be double ball bearing supported and Specially designed, perfectly machined wheel providing correct grip of load chain to makes the hoist most safe and reliable against any failure. The main specifications of C.P Block are given below</p> <p>Make = Pull Lift/Globe</p> <p>Capacity = 2 ton</p> <p>No. Of load chain falls = 2 or above</p> <p>Min. Height of lift = 6 M</p>	1 000	Job	44473 000	44473.00
33	<p>Providing, laying &amp; fixing with adhesive/bonding material of insulation rubber mats on the floor of the pump house, covering area around electro-mechanical machinery for safeguarding the life &amp; limb of the workmen due to possible leakage of current &amp; short circuit. The floor surface shall be made good &amp; shall be free from dust, grease, foreign material &amp; moisture free. The mats shall be as per IS 15652:2006 &amp; shall have the following specifications. -</p> <p>Composition: Rubber (synthetic mats for electrical purpose)</p> <p>Thickness - 2.5mm Size - 1M wide.</p> <p>The rubber mats shall be accepted with manufacturers test certificate.</p>	10.000	Mtr	1205 000	12050.00
34	<p>Providing &amp; Fitting of Dozing pumps to doze required quantity of alum/Chlorine in the system. The capacity of the dozing units shall be 0-12 LPH capacity. Dozing pups shall be provided with all required accessories including 200 ltrs PVC tanks and cable for connection. Each pump shall be provided with 20 mtrs. cable as per required specification.</p>	1.000	Job	15000 000	15000.00
35	<p>Providing and fitting of pressure gauges with adopters to replace damaged ones ,these pressure gauges should be in the range of 0-50 kgf/cm/sg and be reputed make.</p>	1.000	Job	8232.000	8232.00
36	<p>Removal of choked filter media from 5000 GPH pressure filter vessel (02 No.). The job includes all loads and lifts, disposal of choked media to dumping site outside the premises of the plant within a lead of 5 km. The vessel needs to be cleaned properly and dried before laying of fresh media.</p> <p>Providing and laying of filter media of specific size and grade to be laid in 5000 GPH Pressure vessels (02 No) duly washed, free from dust, dirt, loom and any other inorganic material or suspension .the job includes carriage of filter media from Ganderbal to site including all all loads and lifts required on the site condition. The media is to be lad in different layers of specific size and grade from bottom to top over the filter bed plate. The bottom layer is to be laid without tilling/damaging the pressure nozzles.</p> <p>Providing and fitting of 12 mm dia. Fine threaded PVC nozzles auxiliary type to be fitted on filter bed plate of pressure vessels (02 Nos).</p> <p>Providing and fitting of 29 inch. dia. rubber washers /gaskets for manhole and inspection chamber and opening of pressure filter vessel.</p> <p>Providing and fitting of 3"x5/8" nuts and bolts.</p> <p>Overhauling of backwash unit of 5000 Pressure vessel (02 No) by way of dismantling of unit parts assembling cleaning, oiling, greasing, replacement of any damaged parts, refining of sub assemblies &amp; installation of backwash unit with its existing suction &amp; delivery outlet. Job includes P/F of packing &amp; consumables.</p> <p>Overhauling of air scavanging/blower unit 5000 GPH pressure vessel (02 Unit) by way of P/F of reducing pressure weights, filling of oil replacement of pressure valves. job includes oiling, greasing &amp; fitting of consumables.</p> <p>Painting with synthetic enamel paint two or more coats of approved brand and bar pressure clarifier pressure filter vessel, fittings and complete piping after cleaning of dirt by kerosene oil and application of steel primer of specific grade.</p>	1.000	Job	141000.000	141000.00
<b>Total in Figures:</b>		<b>1210081.492</b>			
<b>Say Rs.</b>		<b>12.10 Lac</b>			
<b>Total in Words: Rupees Twelve Lac &amp; Ten Thousand Only.</b>					

Executive Engineer  
 Jal Shakti (PHE) Mechanical Division  
 South Awantipora

Executive Engineer